


2 Technology

2.1 Dimensions - T4



Item	Description	Unit	24/30	40/50	60/75	90/100/110
H	Height of boiler	mm	1390	1620	1620	1720
H1	Total height including flue gas pipe connection		1440	1670	1670	1770
H2	Height, outfeed connection	mm	1195	1425	1425	1530
	Boiler outfeed connection	Zoll	6/4	6/4	6/4	2
H3	Height, return connection	mm	270	270	270	170
	Boiler return connection	Zoll	6/4	6/4	6/4	2
H4	Height, drainage connection	mm	140	140	140	140
	Boiler drainage connection	Zoll	1/2	1/2	1/2	1
H5	Height, rotary valve connection	mm	580	650	650	650
B	Width of boiler	mm	600	770	770	880
B1	Total width with stoker unit		1360	1530	1530	1640
B2	Width, stoker unit		760	760	760	760
B3	Distance from boiler side to stoker connection		470	470	470	470
L	Length, boiler	mm	1200	1200	1570	1570
L1	Total length including ash container and ID fan		1430	1430	1920	1920
L2	Length from back side of boiler to stoker connection		755	755	1045	1045

2.2 Technical specifications

Description	Unit	T4					
		24	30	40	50		
Rated heat output	kW	24	30	40	50		
Heating efficiency range		7,2-24,0	9,0-30,0	12,0-40,0	15,0-50,0		
Electrical connection		400V / 50Hz / C20A					
Electrical consumption	W	45 - 115	54 - 142	51 - 150	47 - 158		
Boiler weight	kg	620	640	840	860		
Boiler water capacity	l	105	105	160	160		
Upstream resistance ($\Delta T = 10 / 20^{\circ}\text{C}$)	mbar	3,9 / 1,2	4,8 / 1,4	5,2 / 1,8	5,5 / 2,2		
Minimum return temperature	$^{\circ}\text{C}$	45					
Maximum permitted boiler operating temperature		90					
Permitted operating pressure	bar	3					
Airborne sound level	dB(A)	< 70					
Boiler class according to EN 303-5: 1999 (pr EN 303-5: 2012)		3 (5)					
Permitted fuel according to EN 14961 ¹⁾		Part 2: wood pellets class A1 / D06 Part 4: wood chips class A2 / P16A-P45A					
Test report data							
Testing institute		TÜV ²⁾		^{3) 4)}		TÜV ²⁾	
Test report no.		10-UW/ Wels-EX- 191/2	10-UW/ Wels-EX- 191/4	-		10-UW/ Wels-EX- 191/5	
Test data – Fuel wood chip		RL	PL	RL	PL	RL	PL
Carbon monoxide (CO)	[mg/MJ]	9 / 28	35 / 28	24,5 / 34	14 / 40		
Nitrogen oxide (NOx)	[mg/MJ]	70 / -	92 / -	88 / -	84 / 64		
Organic Hydrocarbons (OGC)	[mg/MJ]	<1 / 1,3	<1 / 1,3	<1 / <2	<1 / <1		
Dust	[mg/MJ]	13 / -	13 / -	11,5 / -	10 / 7		
Boiler efficiency rating	[%]	92,3 / 91,6	91,0 / 91,6	92,1 / 92,4	93,1 / 93,2		
Test data – Fuel pellets		RL	PL	RL	PL	RL	PL
Carbon monoxide (CO)	[mg/MJ]	8 / 69	7 / 23	<6 / 18	<4 / 12		
Nitrogen oxide (NOx)	[mg/MJ]	70 / -	72 / -	72 / -	71 / 54		
Organic Hydrocarbons (OGC)	[mg/MJ]	<1 / 1,4	<1 / <1	<1 / <1	<1 / <1		
Dust	[mg/MJ]	11 / -	12 / -	10,5 / -	9 / 6		
Boiler efficiency rating	[%]	92,2 / 91,0	92,0 / 91,4	93,1 / 92,3	94,2 / 93,2		

- Detailed information on the fuel is included in the operating instructions, in the section on "Permitted fuels"
- TÜV Austria Services GmbH, Environment and Chemistry Division, Am Thalbach 15, A-4600 Thalheim/Wels
- In accordance with ÖNORM / DIN EN 303-5, Kap. 5.1.3 type test: for a boiler from a range with a consistent structure it is sufficient, if the ratio of rated heat output from the largest to the smallest boiler $\leq 2 : 1$, to carry out the tests with the smallest and the largest boilers. The boiler manufacturer must ensure that all boilers, including those that have not been tested in a range, whose values have been determined depending on rated heat output by interpolation, fulfil the requirements of the norm.
- Values of the model T4 - 40 are interpolated between the test protocol 10-UW/Wels-EX-191/4 and 10-UW/Wels-EX-191/5!

		T4										
Description	Unit	60		75		90		100		110		
Rated heat output	kW	60		75		90		100		110		
Heating efficiency range		18 – 60		22,5 – 75		27 – 90		30 – 100		33 - 110		
Electrical connection	400V / 50Hz / C20A											
Electrical consumption	W	51 - 176		56 - 204		61 - 232		65 - 250		65 - 250		
Boiler weight	kg	1060		1060		1350		1360		1370		
Boiler water capacity	l	220		220		260		260		260		
Upstream resistance ($\Delta T = 10 / 20^{\circ}\text{C}$)	mbar	7,8 / 2,6		11,4 / 3,2		14,9 / 3,8		17,2 / 4,2		18,7 / 5,2		
Minimum return temperature	$^{\circ}\text{C}$	45										
Maximum permitted boiler operating temperature		90										
Permitted operating pressure	bar	3										
Airborne sound level	dB(A)	< 70										
Boiler class according to EN 303-5:1999 (pr EN 303-5: 2012)	3 (5)											
Permitted fuel according to EN 14961 ¹⁾	Part 2: wood pellets class A1 / D06 Part 4: wood chips class A2 / P16A-P45A											
Test report data												
Testing institute	2) 3)						TÜV ⁴⁾		TÜV ⁴⁾			
Test report no.	-						10-UW/ Wels-EX- 191/6		10-UW/ Wels- EX- 191/7			
Test data- Fuel wood chip		RL	PL	RL	PL	RL	PL	RL	PL	RL	PL	
Carbon monoxide (CO)	[mg/MJ]	12,6 / 33,2		10,5 / 23		8,4 / 12,8		7 / 6		7 / 6		
Nitrogen oxide (NOx)	[mg/MJ]	82 / 65		79 / 68		76 / 70		74 / 71		74 / 71		
Organic Hydrocarbons (OGC)	[mg/MJ]	<1 / <1		<1 / <1		<1 / <1		<1 / <1		<1 / <1		
Dust	[mg/MJ]	10,6 / 7,6		11,5 / 8,5		12,4 / 9,4		13 / 10		13 / 10		
Boiler efficiency rating	[%]	93,1 / 93,3		93,0 / 93,6		92,9 / 93,8		92,9 / 93,9		92,9 / 93,9		
Test data – Fuel pellets		RL	PL	RL	PL	RL	PL	RL	PL	RL	PL	
Carbon monoxide (CO)	[mg/MJ]	5 / 11,6		6,5 / 11		8 / 10,4		9 / 10		9 / 10		
Nitrogen oxide (NOx)	[mg/MJ]	70 / 53		69 / 53		68 / 52		67 / 51		67 / 51		
Organic Hydrocarbons (OGC)	[mg/MJ]	<1 / <1		<1 / <1		<1 / <1		<1 / <1		<1 / <1		
Dust	[mg/MJ]	10 / 7		11,5 / 8,5		13 / 10		14 / 11		14 / 11		
Boiler efficiency rating	[%]	94,1 / 93,5		93,9 / 93,9		93,8 / 94,3		93,7 / 94,6		93,7 / 94,6		

- 1) Detailed information on the fuel is included in the operating instructions, in the section on "Permitted fuels"
- 2) In accordance with ÖNORM / DIN EN 303-5, Kap. 5.1.3 type test: for a boiler from a range with a consistent structure it is sufficient, if the ratio of rated heat output from the largest to the smallest boiler $\leq 2 : 1$, to carry out the tests with the smallest and the largest boilers. The boiler manufacturer must ensure that all boilers, including those that have not been tested in a range, whose values have been determined depending on rated heat output by interpolation, fulfil the requirements of the norm.
- 3) Values of the models T4-60, T4-75 and T4-90 are interpolated between the test protocol 10-UW/Wels-EX-191/5 and 10-UW/Wels-EX-191/6!
- 4) TÜV Austria Services GmbH, Environment and Chemistry Division, Am Thalbach 15, A-4600 Thalheim/Wels